Board of Health
Meeting Minutes
August 11, 1987

Present: Ellen Foberg, George Riggan, Marion Boggs, Melissa Quinn

The meeting was called to order at 7:34 P.M.

Mr. Riggan reported that he has consulted with John Brickett (Health Agent/Sanitarian) in regards to the request from Carol Bolduc for on out-of-season percolation test in order that she might upgrade the septic system at her property on Ford Hill Road. Mr. Brickett's recommendation was that the Board allow any system to be upgraded at any time of year. Mr. Riggan felt that to make an exception to the regulation for this purpose would, in essence, defeat the intention of the rule and also make it difficult to argue against such exceptions for new construction. The Board expressed it's unanimous concurrence with Mr. Riggan.

Mrs. Foberg reported that the Rowe Camp and Conference Center has requested that the Board allow them to construct only one septic system to serve the "Infirmary" instead of the two systems as designed by the Sanitarian. Mrs. Foberg pointed out that plans called for a Jacuzzi which would likely be used by more than just the persons using the infirmary. The two systems would better handle the large volumes of waste water created by the whirlpool in addition to the periodic overcrowded conditions. There was a motion to require that two systems be constructed, as originally designed. The motion was seconded and approved.

Water sample results were received from Berkshire Enviro-Labs for the beach and the pitcher pump at the lake. Both were satisfactory and copies will be made available to the Park Commission.

Mr. Brickett has been consulted regarding the capacity of the Fire Station/Garage septic system, and whether it

contacting James Williams, the contractor that made the installation. Mr. Riggan called Mr. Williams and was told that when the system was installed, it was constructed larger than requirements demanded in the event that the Town Hall would at some later time be added. In light of this information, there was a motion to inform Jack Frazier (Juster Pope Architects) that the septic system for the expanded Town Hall can be connected to the existing system behind the Fire Station. The motion was seconded and approved unanimously.

The Meeting adjourned at 7:45 P.M.

Respectfully submitted,
Melissa Quinn, Clerk

Approved:

Ellen L. Foberg

Ellen L. Foberg

George A. Riggan

George A. Riggan

Marion W. Boggs

Marion W. Boggs