Board of Health
Meeting Minutes
March 27, 1990

Present: Ellen Foberg, George Riggan, Marion Boggs, Melissa Quinn

The meeting was called to order at 8:35 P.M.

It was voted unanimously to accept a proposal by Joseph Palmeri for installation of flood lights at the Refuse Garden at a cost of $735 plus $20 for tamper proof lens fasteners. (see file)

Mrs. Foberg suggested that there might be a more cost effective method of recycling cardboard than putting it in the recycling bin. She will look into this and report at a later meeting.

It was noted that Town Nurse Sharleen Moffatt had performed radon testing in town buildings over the previous weekend. Results will be reported as soon as they are received. Mrs. Quinn was directed to write Mrs. Moffatt a note from the Board expressing their appreciation for taking on this job.

A letter was received from the Department of Environmental Protection confirming the survey response to the Yankee Atomic sanitary survey. (see attached)

The meeting adjourned at 8:55 P.M.

Respectfully submitted,
Melissa S. Quinn, Clerk

Approved:

Ellen L. Foberg

Ellen L. Foberg, Chairman

George A. Riggan

George A. Riggan

Marion W. Boggs

Marion W. Boggs

DANIEL S. GREENBAUM
Commissioner
JOHN J. HIGGINS
Regional Director

The Commonwealth of Massachusetts
Executive Office of Environmental Affairs
Department of Environmental Protection
Western Region
436 Dwight Street, Springfield, Mass. 01103
(413) 784-1100

file

March 22, 1990

Yankee Atomic Electric Company
HC 87-Box 160
Rowe, MA 01367

Re: Rowe
Yankee Atomic Electric Company
PWS ID# 1253001
Sanitary Survey Response

Gentlemen:

The Department has reviewed the Yankee Atomic Electric Company's January 12, 1989 response ("Survey Response") to the Department's December 11, 1989 Sanitary Survey Report. Listed below are the Department's comments on specific sections of the Survey Response:

1. Regarding section 2B: Please note that the VOC sampling requirement was due to the location of parking lots, driveways, and transformer storage with Zone I of the well.

2. Regarding section 15: Please inform this office by May 1, 1990 on the Company's decision regarding the relocation of the transformers stored on a concrete pad within 100 feet of the well.

3. It was noted that the Contingency plan is being drafted and should be completed by March, 1990. The submittal date of February 11, 1990 will not however be able to be met.

All other sections of the Survey Response are acceptable to the Department at this time.

The Department will continue to monitor the progress of any corrections scheduled in your response and expects all proposed dates to be met so that the system remains in compliance. Please notify this office upon the completion of each scheduled project.

If you have any questions regarding this matter please contact Bill Prendergast of this office.

Very truly yours,

Roland J. Dupuis

Roland J. Dupuis, P.E.
Regional Engineer
Bureau of Resource Protection

PJN/gm
WS 001/ssrryaec

cc: DEP-DWS-Boston
Board of Health-Rowe