Board of Health
November 14, 1995
Meeting Minutes

Present: Leonard Laffond, Jeffrey Taskey, Melissa Quinn
Absent: Ellen Foberg

The meeting was called to order at 1:30 PM.

It was reported that a percolation test was conducted 11/9/95 at the Karl and Pearl Jurentkuff property on Newell Cross Road (Map 1, Lot 50) for a failed septic system. The test was successful with a percolation rate of 30 minutes per inch. Those in attendance were Mr. Laffond, Mr. Taskey, John Brickett, RS., Tom Danek and Mike Lavigne.

A septic system inspection was conducted by Kathy Bridges at the Richard and Jacqueline Howe property also on Newell Cross Road (Map 1, Lot 10) on the same day. The system passed the inspection.

The meeting adjourned at 1:40 PM.

Respectfully submitted,
Melissa S. Quinn, Administrative Assistant

Approved:

___(absent) Ellen Foberg
Ellen L. Foberg, Chairman

Leonard J. Laffond
Leonard J. Laffond

Jeffrey A. Taskey
Jeffrey A. Taskey